

# WEST WENDOVER WATER SYSTEM

Consumer Confidence Report – 2024

Covering Calendar Year – 2023

## Spanish (Español)

Este informe contiene información muy importante sobre la calidad de su agua de beber. Tradúscalo o hable con alguien que lo entienda bien. Par más información llame a Raul Naranjo 775-664-3363

This brochure is a snapshot of the quality of the water that we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. It is important that customers be aware of the efforts that are continually being made to improve their water systems.

**For more information, please contact Raul Naranjo at 775-664-3363.**

Your water comes from:

| Source Name    | Source Water Type |
|----------------|-------------------|
| SHAFTER 1 WELL | Ground Water      |
| SHAFTER 2 WELL | Ground Water      |
| SHAFTER 3 WELL | Ground Water      |
| SHAFTER 4 WELL | Ground Water      |
| SHAFTER 5 WELL | Ground Water      |
| SHAFTER 6 WELL | Ground Water      |
| PEQUOP 1 WELL  | Ground Water      |
| PEQUOP 2 WELL  | Ground Water      |

We add disinfectant to protect you against microbial contaminants. The Safe Drinking Water Act (SDWA) requires states to develop a Source Water Assessment (SWA) for each public water supply that treats and distributes raw source water in order to identify potential contamination sources. The state has completed an assessment of our source water. For the results of the source water assessment, please contact us.

## Message from EPA

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides may come from a variety of sources such as stormwater run-off, agriculture, and residential users.

Radioactive contaminants can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, may also come from gas stations, urban stormwater run-off, and septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulation that limits the amount of certain contaminants in water

provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protections for public health.

Our water system tested a minimum of 7 samples per month in accordance with the Revised Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public via newspaper, television, or radio.

While your supplied water meets the EPA's standard for Lead, *if present at elevated levels* this contaminant can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your Water System is responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Water Quality Data

The tables below list all of the drinking water contaminants that were detected during the 2023 calendar year. Testing was done between January 1- to December 31, 2023. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

**Arsenic:** The following health effects information is required because our last arsenic test was above half the MCL. Again, the bottom line is that the water that is provided to you is safe to drink.

*Arsenic* occurs naturally in the environment and as a by-product of some agricultural and industrial activities. It can enter drinking water through the ground or as runoff into surface water sources. Although short-term exposures to high doses (about a thousand times higher than the drinking water standard) cause adverse effects in people, such exposures do not occur from public water supplies in the U.S. that comply with the arsenic MCL. Some people who drink water containing arsenic in excess of EPA's standard over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.

## Terms & Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Action Level (AL):** the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

**Treatment Technique (TT):** a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL):** the highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for the control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Parts per Million (ppm)** or milligrams per liter (mg/l)

**Parts per Billion (ppb)** or micrograms per liter (µg/l)

**Picocuries per Liter (pCi/L):** picocuries per liter is a measure of the radioactivity in water.

**Millirems per Year (mrem/yr):** the measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL):** a million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU):** nephelometric turbidity unit is a measure of the clarity of the water. Turbidity in excess of 5 NTU is just noticeable to the average person.

| Disinfection By-Products | Monitoring Period | RAA | Range       | Unit | MCL | MCLG | Typical Source                            |
|--------------------------|-------------------|-----|-------------|------|-----|------|-------------------------------------------|
| HAA5                     | 2023              | ND  | No Detected | µg/L | 60  | 0    | By-product of drinking water chlorination |
| TTHM                     | 2023              | ND  | No Detected | µg/L | 80  | 0    | By-product of drinking water chlorination |

| Lead and Copper | Date | 90 <sup>TH</sup> Percentile |           | Unit | AL   | Sites Over AL | Typical Source                                                                                          |
|-----------------|------|-----------------------------|-----------|------|------|---------------|---------------------------------------------------------------------------------------------------------|
| COPPER          | 2023 | 0.086                       | ND - .124 | ppm  | 1.3  | 0             | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives. |
| LEAD            | 2023 | .00                         | ND - .002 | ppm  | .015 | 0             | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives. |

| Regulated Contaminants | Collection Date | Highest Value | Range      | Unit | MCL | MCLG | Typical Source                                                                                          |
|------------------------|-----------------|---------------|------------|------|-----|------|---------------------------------------------------------------------------------------------------------|
| ARSENIC                | 2022            | 6             | 3-6        | ppb  | 10  | 0    | Erosion of natural deposits; runoff from orchards; Runoff from glass and electronics production wastes. |
| BARIUM                 | 2022            | 0.15          | .08 - .15  | mg/L | 2   | 2    | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.             |
| FLUORIDE               | 2023            | 0.6           | 0.6        | mg/L | 2   | 4    | Natural deposits: Water additive which promotes strong teeth.                                           |
| NITRATE                | 2023            | 2.12          | .53 – 2.12 | mg/L | 10  | 10   | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.            |
| NITRITE                | 2023            | ND            | ND         | mg/L | 1   | 1    | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.            |
| THALLIUM               | 2022            | .6            | .6         | ppb  | 2   | 2    | Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories.              |
| SELENIUM               | 2023            | 0.001         | .001       | ppb  | 50  | 50   | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines        |

| Radionuclides                 | Collection Date | Highest Value | Range   | Unit  | MCL | MCLG | Typical Source                         |
|-------------------------------|-----------------|---------------|---------|-------|-----|------|----------------------------------------|
| COMBINED RADIUM (-226 & -228) | 2023            | 0.6           | 0.6     | pCi/L | 5   | 0    | Erosion of natural deposits            |
| COMBINED URANIUM              | 2023            | 13            | 9.1- 13 | µg/L  | 30  | 0    | Erosion of natural deposits            |
| GROSS ALPHA, INCL. RADON & U  | 2023            | 6.0           | 6.0     | pCi/L | 15  | 0    | Decay of natural and man-made deposits |
| RADIUM - 226                  | 2023            | -0.09         | -0.09   | pCi/L | 5   | 0    | Decay of natural and man-made deposits |
| RADIUM - 228                  | 2023            | 0.6           | 0.6     | pCi/L | 5   | 0    | Decay of natural and man-made deposits |

| Secondary Contaminants | Collection Date | Highest Value | Range       | Unit   | SMCL      | MCLG |
|------------------------|-----------------|---------------|-------------|--------|-----------|------|
| CHLORIDE               | 2022            | 18            | 9-18        | mg/L   | 400       |      |
| MAGNESIUM              | 2022            | 12            | 11 - 12     | mg/L   | 150       |      |
| MANGANESE              | 2022            | 0.015         | 0 - .015    | mg/L   | 0.1       |      |
| pH                     | 2022            | 8.2           | 8 – 8.2     | pH     | 6.5 - 8.5 |      |
| SODIUM                 | 2022            | 28            | 21 - 28     | mg/L   | 200       | 20   |
| SULFATE                | 2022            | 31            | 24 - 31     | mg/L   | 500       |      |
| TDS                    | 2022            | 256           | 225 - 256   | mg/L   | 1000      |      |
| COLOR                  | 2022            | 25            | 25          | C.U.   | 15        |      |
| ODOR                   | 2022            | 2             | 2           | T.O.N. | 3 TON     |      |
| IRON                   | 2022            | 0.75          | 0.41 – 0.75 | mg/L   | 0.6       |      |
| COPPER                 | 2021            | .006          | .006        | mg/L   | 1.0       |      |

#### Water System

Shafter 3 was placed back in service after repairs to the pump and motor.

In July of 2023 Nevada Division of Environmental Protection conducted a Sanitary Survey of our water system. Based on the survey, 2 significant deficiencies, 2 minor deficiencies, and 1 recommendation have been identified. All except one issue have been corrected or addressed.

The one issue that has not been corrected is a leak that was identified at our 3 Mile water reservoir. We have found that the protective liner is leaking and that it needs to be replaced. The city has secured funding to make the proper repairs and they will be completed later this year (2024).

#### Violations

Consumer Confidence Report (CCR) Failure to Report in 2023. Although the report for 2023 was printed and distributed in West Wendover. The system operator Raul Naranjo failed to submit it to the NDEP to be filed on record. This violation did not in any way affect the water quality.

This issue has been resolved and the 2023 CCR has been submitted to the state.

For more information contact: Raul Naranjo – City of West Wendover - PO Box 2825 - West Wendover NV 89883  
Tel: 775-664-3363